WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 56710
Permit No.
Basin 212

1. OWNER JOHN SCANDLAND ADDRESS SAGE BRUSH

2. LOCATION SE ¼ NE ¼ Sec 36 T 21 S N/S R 61 E Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐ AIR

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ~~0-5~~ | — | — | — | — |
| SAND | — | 0 | 5 | 5 |
| CLAY + SAND | — | 5 | 160 | 155 |
| GRAVEL (LOOSE) | — | 160 | 185 | 15 |
| HARD GRAVEL SHELF | — | 185 | 205 | 20 |
| CLAY + GRAVEL | — | 205 | 250 | 45 |
| WATER | 35 | | | |
| WATER | 60 | | | |
| " | 90 | | | |
| " | 120 | | | |
| " | 140 | | | |
| " | 148 | | | |
| " | 160 | | | |
| CONSTANT WATER TEST | WELL | | | |

RECEIVED
MAR 31 1980
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started Mar. 26, 19 80
Date completed Mar. 29, 19 80

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 250 feet
Casing record
Weight per foot Thickness 10 gauge

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | +1' feet | 250' feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type CEMENT
Depth of seal 50 ft feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 250 feet

Perforations:
Type perforation TORCH-CUT
Size perforation 1/8" x 16" x STAGGERED
From 150 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 ft Feet below land surface 6 ft
Flow G.P.M.
Water temperature COOL °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES A. DIMICK
Address 4375 N. TIOGA
Nevada contractor's license number 10062
Nevada driller's license number 995
Signed Charles A. Dimick
Date Mar 30, 1980

USE ADDITIONAL SHEETS IF NECESSARY

O-627

01505
916