WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56743
Permit No.
Basin 212

NOTICE OF INTENT NO. 11735

1. OWNER National Park Service
MAILING ADDRESS Callville Bay, NV.
ADDRESS AT WELL LOCATION Callville Bay, NV.

2. LOCATION SE ¼ SW ¼ Sec. 16 T. 21S N/S R. 65 E. Clark County
PERMIT NO. W-2064 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Caliche		0	5	
Gravel		5	15	
Silty gravel		15	95	
Silty clay		95	100	
Gravel		100	120	
Silty sand		120	165	
Silty clay		165	175	
Sand		175	183	
Sand & silt		183	190	
Sand		190	200	

RECEIVED
MAY 17 1995
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-7, 19 95
Date completed 4-13, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
75	13'8"	

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	200

Perforations:
Type perforation machine
Size perforation 1/8" X 2½"
From 125 feet to 160 feet
From 175 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 200 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Briner Drilling Inc. (Contractor)
Address 555 N. Parkson Rd. (Contractor)
Henderson, NV. 89015
Nevada contractor's license number issued by the State Contractor's Board 6294A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1338
Signed M. D. Briner (By driller performing actual drilling on site or contractor)
Date May 13, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

RECE'

919
PAJH3