WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

56755
OFFICE USE ONLY
Log No.
Permit No.
Basin

1. OWNER J. Lynne Whipple ADDRESS 1816 Shaner Lane
Las Vegas, Nevada 89110

2. LOCATION NW ¼ SE ¼ Sec. 21 T. 20 N/S R. 62 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	10	10
Sandy clay		10	40	30
Gravel		40	60	20
White clay		60	200	140

RECEIVED
JUN 17 1981
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started May 13, 1981
Date completed May 19, 1981

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 200 feet
Casing record
Weight per foot Thickness .250

Diameter	From	To
8 inches	+1 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 3" 8 rows 6" centers
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 90 Feet below land surface
Flow G.P.M.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC.
Address 3215 Cinder Lane
Las Vegas, Nevada 89103

Nevada contractor's license number 4286A

Nevada driller's license number 582

Signed Richard K. Thompson

Date May 21, 1981

USE ADDITIONAL SHEETS IF NECESSARY

O-627