WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56848
Permit No.
Basin 37A

NOTICE OF INTENT NO. 21771

1. OWNER Mc Pherson Family Trust
MAILING ADDRESS 507 Polk Street, Suite 240
San Francisco Cal 94102

ADDRESS AT WELL LOCATION NAF Ranchette Well
Walls Canyon Rd

2. LOCATION ¼ SE ¼ Sec. 9 T. 9 N/S R. 43 E. Nye County

PERMIT NO. (Issued by Water Resources) Parcel No. 2 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	38	38
Clay		38	40	2
Sand + Gravel w/ Lenses of Clay		40	70	30
Sandy Clay + Rock		70	74	4
Cemented Sand + Gravel		74	76	2
Sandy Clay + Gravel		76	91	5
Sand + Gravel		91	112	21
Coarse Sand		112	174	62
Clay		174	178	4
Sand + Gravel		178	181	3
Clay		181	185	4
Sand + Gravel		185	198	13
Clay		198	211	13
Sand + Gravel		211	220	9
Sand Stone w/ Rock		220	228	8
Sand + Gravel w/ Thin Layers of Clay		228	273	45
Sand Stone w/ Boulders	240' ↓	273	278	5
	300	278	300	22

Date started ....., 19.....
Date completed ....., 19.....

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	0	4 HR

8. WELL CONSTRUCTION
Depth Drilled 304 Feet Depth Cased 304 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	240 Feet
8 Inches		240 Feet	304 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1.5	303

Perforations: Mill Slotting
Type perforation 8 Rows Machine
Size perforation .125 x 2½
From 240 feet to 298 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100' feet to 240' feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Delon Winsor (Contractor)
Address PO 116 Silver Peak, Nev (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 35005
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 783
Signed Delon Winsor (By driller performing actual drilling on site or contractor)
Date 2-19-95

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627