

OFFICE USE ONLY  
 Log No. 56853  
 Permit No. \_\_\_\_\_  
 Basin 106  
 NOTICE OF INTENT NO. 29388

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Doug Dee's Construction ADDRESS AT WELL LOCATION 3691 Quail Run Trail  
 MAILING ADDRESS Box 2782 Minden NV  
 2. LOCATION SE 1/4 SW 1/4 Sec 15 T. 10 N/S R 22 E LYON County  
 PERMIT NO. 37-630-10 Parcel No. Quail Run Trail Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders, Sand		0	25	25
Boulders w/ streaks of Clay		25	50	25
Sand, Cobbles		50	75	25
Boulders, Cobbles, Clay Streaks		75	100	25
Sand, Washed Gravel	*	100	100	0

8. WELL CONSTRUCTION  
 Depth Drilled 120 Feet Depth Cased 11 to 120 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 120 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>1 8/8</u>	<u>11</u>	<u>120</u>

Perforations:  
 Type perforation Factory milled  
 Size perforation 3/32  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 120 feet

9. WATER LEVEL  
 Static water level N/A feet below land surface  
 Artesian flow N/A G.P.M. 15 P.S.I.  
 Water temperature Cold °F Quality Clear

Date started 4-18, 1996  
 Date completed 4-19, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>15</u>	<u>N/A</u>	<u>1</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Enbe Dalling Contractor  
 Address Po Box 1345 Dayton NV 89403 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 1439A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1757  
 Signed Troy Enloe  
 By driller performing actual drilling on site or contractor  
 Date 5-6-96