

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28471

1. OWNER BIFF PLEMEL ADDRESS AT WELL LOCATION 2043 COMSTOCK
 MAILING ADDRESS MINDEN, NV TOPAZ LAKE, NV

2. LOCATION SE 1/4 NW 1/4 Sec. 32 T. 10 N. R. 22 E. DOUGLAS County
 PERMIT NO. _____ Parcel No. 39-173-11 Subdivision Name TOPAZ LAKE
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SHAEL / SMALL GRAVEL	0	40	41	41
GRAVEL / COBBLES	1	41	48	7
SHAEL / SMALL GRAVEL		48	51	3
GRAVEL		51	62	11
BASALT FRAGMENTS		62	77	15
BASALT		77	81	4
SAND / GRAVEL	✓	81	93	12
BASALT FRAGMENTS		93	94	2
GRAVEL / SAND	✓	94	98	4
BASALT		98	104	6
GRAVEL / SAND	✓	104	112	8
SANDY CLAY		112	113	1
BASALT FRAGMENTS	✓	113	120	7
GRAVEL / SAND	✓	120	160	40

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	To	Feet
<u>10 5/8</u>	0	100	100
<u>9 7/8</u>	100	160	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.38</u>	<u>+1</u>	<u>160</u>

Perforations:

Type perforation FACTORY SLETTED
 Size perforation 1/8 x 3

From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 100 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 100 feet to 160 feet

Date started 7/26, 1996
 Date completed 8/7, 1996

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>

9. WATER LEVEL

Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD OF Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC
 Contractor
 Address 879 RITZER DR
CARDONVILLE, NV 89410
 Contractor
 Nevada contractor's license number 27673A
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1997
 Division of Water Resources, the on-site driller
 Signed David [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-7-96