WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 56862
Permit No.
Basin

NOTICE OF INTENT NO. 27429

PRINT OR TYPE ONLY

1. OWNER John Morris
MAILING ADDRESS 1846 Genoa Lane Lake Tahoe Gardnerville Nev. 89410
ADDRESS AT WELL LOCATION 1846 Genoa Lane Gardnerville Nev. 89410

2. LOCATION S.E. ¼ N.E. ¼ Sec. 29 T. 10 N/S R. 23 E. Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. 34-010-06 Subdivision Name none

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
yellow abundant dust + sharp rock		0	55	55
sharp gravel	yes	55	70	15
yellow fine sand		70	87	17
sharp gravel + rock	yes	87	105	18
rock + yellow clay		105	130	25
gravel + rock	yes	130	150	20

RECEIVED 96 SEP 10 AM 11:31 STATE ENGINEER'S OFFICE

Date started Aug 27, 1996
Date completed Sept 4, 1996

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	20 T	16 ft	6 hrs

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 150 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness 188

Diameter	From	To
6 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement grout
Depth of seal 50 ft feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation factory saw slott
Size perforation 3/32 x 3
From 100 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 55 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edward Mills (Contractor)
Address Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada contractor's driller's number issued by the Division of Water Resources 715
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edward Mills (By driller performing actual drilling on site or contractor)
Date Sept 5 1996

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627