

OFFICE USE ONLY
 Log No. 56876
 Permit No. _____
 Basin. 137B
 NOTICE OF INTENT NO. 31547

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Round Mountain Gold Corp ADDRESS AT WELL LOCATION South Pad
 MAILING ADDRESS PO Box 480
Round Mountain, NV. 89045
 2. LOCATION NW 1/4 SW 1/4 Sec. 35 T. 10 N. R. 43 E Nye County
 PERMIT NO. MO 992 C
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite wash		0	170	
clay		170	180	
Small gravel	✓	180	200	
Granite wash/clay		200	220	
Large gravel	✓	220	240	
Small gravel	✓	240	280	
Granite wash w/ lots of clay stringers		280	300	

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
1 3/4 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/4</u>	<u>28.04</u>	<u>.1250</u>	<u>0</u>	<u>50</u>
<u>6 5/8</u>	<u>12.85</u>	<u>.188</u>	<u>+1</u>	<u>300</u>

Perforations:
 Type perforation stuffed wire wrap high carbon
 Size perforation Johnson well screen 100 s/ft
 From 180 feet to 200 feet
 From 220 feet to 240 feet
 From 260 feet to 280 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow 60 G.P.M. _____ P.S.I.
 Water temperature C °F Quality good

Date started 7-5, 1996
 Date completed 7-13, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Waytek Drilling Co. Inc. Contractor
 Address 2220 Stowe Dr. Contractor
Reno, NV. 89511
 Nevada contractor's license number 024521
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1442
 Division of Water Resources, the on-site driller
 Signed Joe Waytek
 By driller performing actual drilling on site or contractor
 Date 7-18-96