

OFFICE USE ONLY
 Log No. 36891
 Permit No. 108
 Basin 108
 NOTICE OF INTENT NO. 27712

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER John Namer ADDRESS AT WELL LOCATION 770 NW 208 MASON VALLEY
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec. 24 T. 12 N. S. R. 25 E LYON County
 PERMIT NO. 12-351-13 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	5	
GRVL W/ COBBLESTONE		5	65	
CLAY & GRVLS		65	75	
SAND W/ GRVLS		75	135	
GRVLS	WB	135	200	

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
9 7/8 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3/32
 From 100 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 200 feet to 100 feet

9. WATER LEVEL
 Static water level 10 feet below land surface
 Artesian flow _____ G.P.M. 50 P.S.I.
 Water temperature COOL °F Quality GOOD

Date started 9-23, 1996
 Date completed 9-28, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>UNK</u>	<u>2 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Smith Valley Drilling / Phil Brown Contractor
 Address 83 Hudson Aurora Contractor
Smith, NV
 Nevada contractor's license number issued by the State Contractor's Board 41673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1949
 Signed Phil Brown
 By driller performing actual drilling on site or contractor
 Date 9-30-96

RECEIVED
 96 OCT 21 AM 11:38
 STATE ENGINEERS OFFICE