WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

DW#6

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56892
Permit No.
Basin 137B

NOTICE OF INTENT NO. 31346

1. OWNER Round Mountain Gold Corp
MAILING ADDRESS PO Box 480
Round Mountain, Nv. 89045

ADDRESS AT WELL LOCATION IN MINE PIT

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 10 N/S R. 44 E. Nye County
PERMIT NO. 44299 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial (MINING) ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Plug And Abandon				
Pour into well (between csg & bore)				
53 sks of hole plug (300' up to 72') top of ground				
This is 15' Lower Than the 57' of 12¾" Surface csg. That was cemented in,				
Pour into 8⅝" Production csg. 220 sks hole plug up to 50'.				
Mix 30 sks Neat Cement, Pour into well, - Filled Well -				

Date started 6-26, 1996
Date completed 6-27, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	N/A	

8. WELL CONSTRUCTION
Depth Drilled 680 Feet Depth Cased 680 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
17½	0	57
10¾	50	680

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12¾	33.38	.250	+1	57
8¾	22.36	.250	+2	680

Perforations:
Type perforation Roscoe Moss shutter screen
Size perforation .187 X 2½
From 300 feet to 680 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 57'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ~~☒ No~~
From 300 feet to 680 feet

9. WATER LEVEL
Static water level 640' At Time of Abandon feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Woytek Drilling Co. Inc.
Address (Contractor) 2220 Stowe Dr
Reno, Nv. 89511
Nevada contractor's license number issued by the State Contractor's Board 024521
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Les Woytek (By driller performing actual drilling on site or contractor)
Date 7-2-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627