WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56900
Permit No.
Basin 178

NOTICE OF INTENT NO. 31340

1. OWNER Ronald Berg
MAILING ADDRESS Round Mountain, NV 89045
ADDRESS AT WELL LOCATION 12 mi South of Springs

2. LOCATION Sw 1/4 SE 1/4 Sec. 29 T. N/S R. 53 E. Nye County
PERMIT NO. 26218 Issued by Water Resources | 10-381-39 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	8	
Brn. Clay		8	12	
small gravel		12	19	
wht. clay		19	30	
gravel		30	34	
Brn clay		34	42	
gravel	✓	42	45	
Brn clay		45	53	
Lg. gravel	✓	53	65	
Brn clay		65	73	
gravel		73	78	
Brn clay		78	94	
Lg. gravel	✓	94	101	
Tan clay		101	135	
gravel	✓	135	143	
yellow clay, some gravel		143	175	
Lg gravel	✓	175	195	
Brn clay, gravel stringers		195	250	
Lg gravel	✓	250	280	
wht clay		280	300	

Date started 3-1, 1996
Date completed 3-14, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	N/A	10

Well has not been pumptested to this date - waiting to abandon old well, after pump test.

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
24	0	20
17 1/2	20	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	52.73	.250	0	20
12 3/4	33.38	.250	+3	300

Perforations:
Type perforation Johnson Agri-Screen
Size perforation
From 95 feet to 105 feet
From 133 feet to 143 feet
From 175 feet to 195 feet
From 277 feet to 280 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Neat Cement Around Conductor Csg.
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 300 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 30 G.P.M. P.S.I.
Water temperature 65 °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne's Drilling (Contractor)
Address 2220 Clowe Dr (Contractor)
Kona, NV. 89511
Nevada contractor's license number issued by the State Contractor's Board 0011201
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1112
Signed Lee Wayne (By driller performing actual drilling on site or contractor)
Date 3-25-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627