WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 56915
Permit No.
Basin 207

NOTICE OF INTENT NO. 2[illegible]973

1. OWNER Justin PARKER
MAILING ADDRESS Rt 1 Box 78 B PARKER A.Z. 85344
ADDRESS AT WELL LOCATION 410 South 100 East Lund NV.

2. LOCATION SE ¼ SE ¼ Sec. 33 T. 12 N/S R. 62 E White Pine County
PERMIT NO. N/A (Issued by Water Resources) 6-035-04 (Parcel No.) Lund town site (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
clay gravel con.		1	24	
gravel conglomerate		24	27	
clay		27	33	
gravel con.		33	36	
clay con.		36	57	
gravel con	water	57	63	
clay		63	71	
gravel c.	water	71	73	
clay		73	77	
gravel	water	77	79	
clay		79	85	
gravel	water	85	86	
clay		86	89	
gravel	water	89	90	
clay		90	98	
gravel	water	98	100	

Date started February 12, 1996
Date completed March 29, 1996

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	1hr

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	55 Feet
8 Inches		55 Feet	100 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.97	.188	-1	100

Perforations:
Type perforation mill
Size perforation 6 x 2.8 x 6 row
From feet to feet
From 60 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 100 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NATHAN R MAYNARD (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orson Maynard (By driller performing actual drilling on site or contractor)
Date April 24 - 1996

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627