


Silver Oak Test Hole #3

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 56980  
Permit No. \_\_\_\_\_  
Basin 104



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26919

1. OWNER Carson City ADDRESS AT WELL LOCATION Silver Oak  
MAILING ADDRESS 3300 Butti Way Subdivision in NW Carson City  
Bldg #9, Carson City, NV 89710

2. LOCATION SE 1/4 NW 1/4 Sec 6 T 15 N 20 E Carson County  
PERMIT NO. 60200T 60568T 60205T Silver Oak Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
**See Attached Log**				
39.196640°N				
119.781468°W				
NAD 83 (74)				
NOT # 58674 plugging this well				
'94 DEC -1 AM 141				
STATE ENGINEER				

8. WELL CONSTRUCTION  
Depth Drilled 470 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)  
From 10 Inches To 470 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	18.97	.280	+2	100
6 5/8	18.97	.280	140	180
6 5/8	18.97	.280	320	380
6 5/8	18.97	.280	440	460

Perforations:  
Type perforation Triple Row Mill Slot  
Size perforation 3/32 x 2"  
From 100 feet to 140 feet  
From 180 feet to 320 feet  
From 380 feet to 440 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 55  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 55 feet to 470 feet

9. WATER LEVEL  
Static water level 45 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Norm °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Humboldt Drilling & Pump Co. Inc.  
Address P. O. Box 590  
Winnemucca, NV 89446  
Nevada contractor's license number issued by the State Contractor's Board 015234  
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1713  
Signed C. E. Gaylor  
By driller performing actual drilling on site or contractor  
Date 11-29-94


Date started Oct 5, 1994  
Date completed Oct 8, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100</u>	<u>380</u>	<u>8</u>

LOG # 56980



## Lithology Silver Oaks Test Hole #3

Depth	Description
0-10	Silty clay, silt, fine sand.
10-20	Tan silty clay 30%, silt, fine sand.
20-30	Tan sandy clay 30%, silt, medium to fine sand, orange-brown to white.
30-40	Tan sandy clay 20%, silt, very coarse to medium sand, few orange-brown clasts, some biotite.
40-50	Tan sandy clay 30%, silt, coarse to medium sand, white opaque, biotite.
50-60	Tan sandy clay 30%, silt, coarse to fine sand, biotite, few dark clasts, medisedimentary.
60-70	Tan sandy clay 30%, silt, very coarse to medium sand, some orange-brown clasts, few dark Ms clasts, biotite.
70-80	Tan sandy clay 20%, silt, very coarse to medium sand, few dark Ms clasts, biotite.