WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57034
Permit No.
Basin 101

NOTICE OF INTENT NO. 30146

1. OWNER Manual Leal
MAILING ADDRESS 941 Tiffany Dr.
Fallon, NV 89406

ADDRESS AT WELL LOCATION
6355 Lakeview Dr. Fallon, NV 89406

2. LOCATION NE 1/4 SE 1/4 Sec. 18 T 19N N/S R 28E E Churchill County
PERMIT NO. | Issued by Water Resources | 008-113-27 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	4	4
Sand		4	35	41
Clay		35	46	11
Sand		46	50	4
Gray Clay		50	74	24
Gray Sand		74	82	8
Gray Sand & Clay		82	138	56
Brown/gray Sand		138	146	8

RECEIVED 96 OCT 29 PM 12:41 STATE ENGINEER'S OFFICE

Date started 9/30/96, 19__
Date completed 9/30/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 146 Feet Depth Cased 146 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 "	Inches	0	Feet	146	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	146

Perforations:
Type perforation Mill Cut
Size perforation 1/8
From 140 feet to 146 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 80ft.
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 80 feet to 146 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. 60 P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265
Contractor
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454

Signed Norman Parsons
By driller performing actual drilling on-site or contractor

Date 10-24-96