


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 57035  
 Permit No. \_\_\_\_\_  
 Basin 104  
  
 NOTICE OF INTENT NO. 30453

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Earl Keele ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2301 Lima Lane 4660 Solias Road, Fallon, NV 89406  
 Fallon, NV 89406

2. LOCATION NE 1/4 SE 1/4 Sec. 16 T 18N N/S R 28E E Churchill County  
 PERMIT NO. 006-434-05 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Coarse Sand		0	19	19
Fine Sand		19	31	12
Gray Clay		31	36	5
Sand		36	54	18
Sandy Clay		54	73	19
Coarse Sand	XX	73	78	5
Gray Clay		78	110	32
Black Clay		110	130	20
Sandy Clay		130	138	8
Brown Clay		138	149	11
Brown Coarse Sand & Gravel	X	149	165	16

8. WELL CONSTRUCTION  
 Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 165 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	165

Perforations:  
 Type perforation mill cut  
 Size perforation 1/8  
 From 162 feet to 165 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 165 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454  
 Signed Norman Parsons  
 By driller performing actual drilling on-site or contractor  
 Date 10-24-96

Date started 9/30/96, 19\_\_\_\_  
 Date completed 9/30/96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>1 hr.</u>

RECEIVED  
 90 OCT 29 PM 12:41  
 STATE ENGINEERING OFFICE