WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57038
Permit No.
Basin 088

NOTICE OF INTENT NO. 31797

1. OWNER Bob Gosso
MAILING ADDRESS 220 Red Stone Reno NV. 89512
ADDRESS AT WELL LOCATION 20575 Cooke Dr

2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 17 N/S R. 20 E. Washoe County
PERMIT NO. 00 5575 (Issued by Water Resources) 045-343-07 (Parcel No.) Plastant Valley Est. (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Over Barden Hard pan		0	85	85
Dr.		85	142	55
Black Rijte		142	160	18
Brown Dr.		160	300	140
White Rock	12	300	312	12
Brown Dr.		312	318	6
Broken Black Rock	12	318	330	12

Date started 6-27-96, 19 96
Date completed 7-4-, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15+		1

8. WELL CONSTRUCTION
Depth Drilled 330 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	60	Feet
8 3/4	Inches	60	Feet	330	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14#	188	+1	330

Perforations:
Type perforation Factory Slot
Size perforation 3/16 X 3
From 295 feet to 315 feet
From 315 feet to 330 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 330 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JM Drilling (Contractor)
Address 1859 Hymer Ave (Contractor)
Sparks NV. 89431
Nevada contractor's license number issued by the State Contractor's Board 41172
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1940
Signed David Blanda (By driller performing actual drilling on site or contractor)
Date 7-28-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627