

XX XX

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 57040
Permit No.
Basin 8-102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23995

1. OWNER Lewis Karcher ADDRESS AT WELL LOCATION 3220 Antelope St. Silver Springs, NV 89429
MAILING ADDRESS 213 McKinley Place Ridge wood, NJ 07450
2. LOCATION NW 1/4 NW 1/4 Sec 21 T 17 N 21 E Lyon County Stockton Sub # 2
PERMIT NO. 17-374-05 Parcel No. Stockton Sub # 2 Issued by Water Resources

3. WORK PERFORMED: New Well, Replace, Recondition, Deepen, Abandon, Other
4. PROPOSED USE: Domestic, Municipal/Industrial, Irrigation, Monitor, Stock
5. WELL TYPE: Cable, Rotary, RVC, Air, Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine Brown Sand		0	30	30
Gray Clay		30	36	6
Gray Sand	X	36	55	21
Brown sand + Clay		55	80	25
Fine to coarse + some Brown clay		80	138	58
Gray Clay		138	140	2

STATE ENGINEERS OFFICE
MAR -1 11:09 '94

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet
HOLE DIAMETER (BIT SIZE)
From 10 5/8 Inches To 140 Feet
Inches Feet Feet Feet
Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:
Type perforation Mill
Size perforation 1/8 x 3
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type: Neat Cement, Cement Grout, Concrete Grout
Depth of Seal 50
Placement Method: Pumped, Poured
Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 3.5 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

Date started 2-23 1994
Date completed 2-25 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>18</u>	<u>3</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling & Development Contractor
Address P.O. Box 668 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 2-26-1994