WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57064
Permit No.
Basin 087

NOTICE OF INTENT NO. 30910

1. OWNER AIRPORT SQUARE
MAILING ADDRESS E. PLUMB LN + HARVARD
RENO, NV.
ADDRESS AT WELL LOCATION SAME

2. LOCATION SW ¼ NW ¼ Sec. 1519 T 19 N/S R 20 E WASHOE County
PERMIT NO. OLD M/O #928 (Issued by Water Resources) APN 015-292-32 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other AUGER

6. LITHOLOGIC LOG MW-1

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ON 9/12/96. I FOUND THE WELL TO BE GOOD CONDITION. AFTER REMOVING THE WELL COVER, I THEN DRILLED THE 2" CASING OUT TO A DEPTH OF 20'. I THEN PRESSURE GROUTED THE HOLE WITH NEAT CEMENT, FROM 20' TO SURFACE. | 12.5" | | | |

RECEIVED 96 OCT 15 AM 11:45 STATE ENGINEER'S OFFICE

Date started 9/12, 1996
Date completed 9/12, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| N/A | | |

8. WELL CONSTRUCTION
Depth Drilled 20' Feet Depth Cased 20' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6" Inches | 0' Feet | 20' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | SCH. 40 | PVC | 0' | 20' |

Perforations:
Type perforation FACTORY
Size perforation .020
From 5' feet to 20' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 20'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 12.5' feet below land surface
Artesian flow NO G.P.M. N/A P.S.I.
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ANDRESEN EXPLORATION DRILLING (Contractor)
Address 1635 BELFORD RD (Contractor)
RENO, NV. 89509
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] By driller performing actual drilling on site or contractor
Date 10/2/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627