

OFFICE USE ONLY  
 Log No. 57094  
 Permit No. \_\_\_\_\_  
 Basin. 099

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32226  
 ADDRESS AT WELL LOCATION 15700 dry Valley Rd.  
Reno, NV 89506

1. OWNER Kendall & Lisa Deebler ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 12100 Mt. Anderson \_\_\_\_\_  
Reno, NV 89506 \_\_\_\_\_  
 2. LOCATION SE 1/4 SE 1/4 Sec 11 T 23 N/S R 18 EAST WASHOE County  
 PERMIT NO. 078-184-04 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other rod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray & brown course sand		0	25	
Gray course sand		25	90	
White gravel & gray clay		90	120	
Multi colored gravel & gray clay	x	120	140	
Orange & white gravels	x	140	160	
Multi colored course sand & brown & gray clay		160	166	
T.D. 166'				
1/8 Plate on bottom				

8. WELL CONSTRUCTION  
 Depth Drilled 166 Feet Depth Cased 166 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10-5/8 Inches 0 Feet 166 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	13.92	.188	1 1/2	166
1/8		plate	bottom	

 Perforations:  
 Type perforation Screen Johnson  
 Size perforation .030  
 From 136 feet to 146 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 166 feet to 50 feet

Date started September 24, 1996  
 Date completed September 27, 1996

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1 1/4

9. WATER LEVEL  
 Static water level 1' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature old °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service Inc. Contractor  
 Address 1800 1/2 Frazer Avenue Contractor  
Sparks, NV 89431  
 Nevada contractor's license number issued by the State Contractor's Board 35387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509T-1  
 Signed Tammy Welch  
 By driller performing actual drilling on site or contractor  
 Date Oct 1, 1996

RECEIVED  
 06 OCT - 3 PM 1:08  
 STATE ENGINEERS OFFICE