WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57097
Permit No.
Basin 017

NOTICE OF INTENT NO. 32019

1. OWNER Jane Balderston
MAILING ADDRESS 2202 S. Arlington Ave
Reno, NV 89501

ADDRESS AT WELL LOCATION
Fish Springs

2. LOCATION NW 1/4 NW 1/4 Sec. 5 T 25N N/S R 18E E Washoe County
PERMIT NO. WaCo 5743 (Issued by Water Resources) 074-01-042 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	3	3
Multi colored rock		3	30	27
Brown clay		30	42	12
Multi colored rock & sand		42	70	28
Brown Clay		70	95	25
See next line	X	95	352	257
Multi colored rock w/ brown sand and clay stringers				

RECEIVED 96 OCT -8 PM 1:26 STATE ENGINEER'S OFFICE

Date started 9/13/96, 19__
Date completed 9/27/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-20	–	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 352 Feet Depth Cased 352 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	352	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	352

Perforations:
Type perforation Factory
Size perforation 3/32 x 3"
From 332 feet to 352 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 200+
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 248 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9-30-96