X

WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57106
Permit No.
Basin 045

NOTICE OF INTENT NO. 30364

1. OWNER JIM PERKINS
MAILING ADDRESS 776 NORTHSIDE APT #4
ELKO, NV 89801

ADDRESS AT WELL LOCATION
RABBIT CREEK DR. OFF LAMOILLE HWY

2. LOCATION NE 1/4 SW 1/4 Sec. 23 T 33N N/S R 57E E ELKO County
PERMIT NO. _____ Issued by Water Resources
6-52D-21 Parcel No.
SPECIAL LANDS Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	3	3
BROWN CLAY		3	12	9
SILTSTONE		12	60	48
SAND & GRAVEL	X	60	135	75

RECEIVED
96 OCT -7 PM 2:37
STATE ENGINEER'S OFFICE

Date started 9/16/96
Date completed 9/16/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 135 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	135 Feet
_____ Inches		_____ Feet	_____ Feet
_____ Inches		_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	135

Perforations:
Type perforation MILLSLOT
Size perforation 3/16 X 3
From 115 feet to 135 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 135 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hackworth Drilling, Inc. Contractor
Address P.O. Box 850 Contractor
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] By driller performing actual drilling on-site or contractor
Date 10-1-96

DEEPENED BY LOG 125875