WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 57121
Permit No.
Basin 212

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER John Thompson
MAILING ADDRESS 4390 W. Pebble Rd. L.V. Nev.
ADDRESS AT WELL LOCATION 4390 W. Pebble Rd. L.V. Nev.

2. LOCATION SW ¼ SW ¼ Sec. 18 T. 22 N/S R. 61 E Clark County
PERMIT NO. SW ¼ SW ¼ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil with rocks		0	3	3
Caliche		3	50	47
Cemented gravel		50	160	110
hard shell		160	166	6
Cemented gravel		166	270	104
little sand with clay	270	270	276	6
Sand & gravel with layers of red clay	276	276	310	34
loose layers of gravel with layers of clay	310	310	405	95

RECEIVED
FEB 17 1983
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started July 1, 1982
Date completed July 20, 1982

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 6 inches Total depth 405 feet
Casing record
Weight per foot 17 # Thickness ¼"

Diameter	From	To
6.5 O.D. inches	0 feet	405 feet
8 inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☑
Gravel packed from feet to feet

Perforations:
Type perforation 1" x 5" x 2 rows
Size perforation 8 1" x 5" slots.
From 300' 8 feet to 405 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 230' feet below land surface
Flow G.P.M. P.S.I.
Water temperature 68 °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weimer Drilling (Contractor)
Address 9051 S. Mohawk, L.V. Nev. (Contractor)
Nevada contractor's license number 5962 A
Nevada contractor's drillers number 171
Nevada driller's license number 171 (Actual Driller)
Signed H. V. Weimer (Contractor)
Date Feb. 16, 1983

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434