WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57150
Permit No.
Basin 089

NOTICE OF INTENT NO. 31676

1. OWNER John & Bernice Sheldon
MAILING ADDRESS 7175 San Antonio Rd. Carson City NV. 89706
ADDRESS AT WELL LOCATION 7175 San Antonio Rd. Carson City NV. 89706

2. LOCATION NE SW ¼ SW ¼ Sec. 22 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. 58725 (Issued by Water Resources) 55-190-11 (Parcel No.) Franktown Road (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown overburden		0	9	9
Boulders, Sand Surface Water		9	25	16
Coarse pit Sands and Clay Seams		25	100	75
Hard Granite		100	149	49
Broken Fracture	xx	149	158	9
Coarse Fractures of Granite		158	190	32

Date started 6-4, 1996
Date completed 6-10, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15.36	.188	0	190

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 120 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 105
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 105 feet to 190 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. 50+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) A & H Pump Co.
Address (Contractor) 5551 Hwy 50 E #3 Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Clinton R. Butts (By driller performing actual drilling on site or contractor)
Date 6-11-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627