WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 57298
Rec. ..... 19.....
Well No. .....
Permit No. .....
Do not fill in

Owner: Peter Burnson — Driller: McKesson & Stock

Address: 428 N. 6TH ST, Las Vegas Nevada — Address: 1629 N. Main St, North Las Vegas Nevada — Lic. No. 200

Location of well: ..... ¼ ..... ¼ Sec. ....., T. ..... N/S, R. ..... E, in Clark County

or Sec. 20 T22S R61E E½ S.E.¼ NE¼ NW¼ Mt. Diablo Meridian

Water will be used for: Domestic — Total depth of well: 200

Size of drilled hole: 8 in. to 160 ft. 6in. to 200 — Weight of casing per linear foot: 11, 5

Thickness of casing: 16 Guage — Temp. of water: cool

Diameter and length of casing: 8 inch 160ft 6 inch from 160 yo 200
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure .....

If nonflowing well give depth of standing water from surface: 143 ft.

If flowing well describe control works .....
(Type and size of valve, etc.)

Date of commencement of well: May 7 1955 — Date of completion of well: May 11 1955

Type of well rig: Keystone #50

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	25	25	Cemented Gravel
25	40	15	Brown Clay
40	60	20	Rolling Gravel
60	84	24	Cemented Gravel
84	105	21	Hard Pan
105	135	30	Cemented Gravel
135	145	10	Clay
145	147	3	Water Gravel
147	160	13	Cemented Gravel
160	170	10	Brown Clay
170	178	8	Cemented Gravel
178	189	11	Water Gravel
189	200	11	clay White

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 178 to 189 ft.

Other aquifers
145 to 147

First water at 145 feet.

Casing perforated
from 140 to 200 ft.

Size of perforations
¼ in. slots 6in. long staggered around casing

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6	0	160		Well us cemented from top to 60 feet down .
160	160	200		

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Estimate bailing test at 800 gallons per, hr. with a 2feet draw down, water was coll.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed McKesson & Stook
Well Driller

By Paul McKesson

License No. 200

Dated June 11, 1955

(Not to be filled in by Driller)