DIVISION OF WATER RESOURCES

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 7309
Permit No.
Basin [redacted]

1. OWNER Vick Fouquet ADDRESS 2254 Black Sapphire Av. L.V.

2. LOCATION ~~NE~~ NE ¼ NW ¼ Sec. 20 T. 22 S N/S R. 61 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel (gray)		0	50	50
Sand-gravel (Brown		50	90	40
Red clay		90	110	20
Brown Hard Pan		110	230	120
gravel		230	300	70

RECEIVED
FEB 28 1977
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started ~~Jan~~ Feb 1st, 1977
Date completed Feb 15, 1977

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 12 gpm Draw down 0 feet 2½ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8" inches Total depth 300 feet
Casing record 300'
Weight per foot 12.15 Thickness .134

Diameter	From	To
8 5/8 inches	0 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 300 feet

Perforations:
Type perforation ~~[illegible]~~ Torch
Size perforation 1/8 x 4
From 200 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 190 Feet below land surface
Flow G.P.M.
Water temperature 78 °F. Quality Fair

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Robert E Dresden
Address 4413 E Berkley Las Vegas
Nevada contractor's license number 13577
Nevada driller's license number 797
Signed Robert E Dresden
Date 2-24-77

USE ADDITIONAL SHEETS IF NECESSARY

5471