

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 57655
 Rec.
 Well No.
 Permit No.

T

Do not fill in

Owner Bell & Vivian Dochess Driller Effinger Bros.
 Address Paradise Valley Address 1001 Artesia Way Lic. No. 212
 Location of well: $\frac{1}{4}$ Sec. 2, T. N/S, R. E, in Clark County
 or NE SE NW SECTION 2 T22S R61E
 Water will be used for Domestic Total depth of well 250 feet
 Size of drilled hole 12 Inch Weight of casing per linear foot
 Thickness of casing 10 Guage Temp. of water
 Diameter and length of casing 8"OD 250 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure
 If nonflowing well give depth of standing water from surface 9'7" from top of casing
 If flowing well describe control works
(Type and size of valve, etc.)
 Date of commencement of well September 26, 1955 Date of completion of well October 4, 1955
 Type of well rig "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
			Pulled out 6" well casing & cleaned out well to depth of 90 feet. No cement in hole.
90	96	6	Red Clay
96	99	3	Sandstone
99	110	11	Red Clay & Gravel
110	117	7	Yellow Clay
117	123	6	Red Clay
123	125	2	Sandstone
125	145	20	Red Sticky Clay
145	148	3	Sandstone (Water)
148	161	13	Red Clay
161	168	7	Sandstone (Water)
168	179	11	Red Sticky Clay & Gravel
179	187	8	Gravel (Water)
187	196	9	Red Clay
196	204	8	Sticky Clay
204	215	11	Clay & Gravel
215	250	35	Gravel (Water)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
 from 215 to 250 ft.

Other aquifers 179-187
161-168
145-148

First water at feet.

Casing perforated
 from 80 to 250 ft.

Size of perforations
1/8" X 12"

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"OD	0	250	250	Cemented from 0 to 80 feet Perforated from 80 to 250 feet Graveled packed from 80 to 250 feet 6 yards of pea gravel 3 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Bros.
Well Driller

By A. F. Effinger
License No. 212

Dated October 4, 19 55

(Not to be filled in by Driller)
