WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57794
Permit No.
Basin 162
NOTICE OF INTENT NO. 15125

1. OWNER SUNDANCE HOMES
MAILING ADDRESS 2311 W LABRADOR
PAHRUMP, NV 89041

ADDRESS AT WELL LOCATION 2311 W LABRADOR

2. LOCATION NW 1/4 SE 1/4 Sec. 31 T 20S N/S R 53E E NYE County
PERMIT NO. _____ Issued by Water Resources | 36-471-59 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & CALICHIE		0	75	75
CALICHIE	WB	75	85	10
CLAY		85	108	23
CALICHIE	WB	108	120	12
CLAY		120	137	17
CALICHIE	WB	137	140	3

Date started 10/1/96, 19__
Date completed 10/4/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 100 feet to 120 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surfac
Artesian flow ____ G.P.M. ____ P.S.I
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Co. (Contractor)
Address PO BOX 4220 (Contractor)
PAHRUMP, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dim (By driller performing actual drilling on-site or contractor)
Date 10/17/96

NOV 21 1996