WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57863
Permit No.
Basin 21

NOTICE OF INTENT NO. 16007

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 1001 S. Valley View Blvd. Las Vegas NV 89153
ADDRESS AT WELL LOCATION Well #113 3901 Constantinople Ave Las Vegas NV

2. LOCATION NE ¼ NE ¼ Sec. 8 T. 20-S N/S R. 60 E. Clark County
PERMIT NO. ____ Resources | 138-07-501-014 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness

RECEIVED 96 OCT 21 PM 1:30 STATE ENGINEER'S OFFICE

OCT 29 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2250	69.25	24

Date started 1-19, 1996
Date completed 6-6, 1996

8. WELL CONSTRUCTION
Depth Drilled 1222 Feet Depth Cased 1200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
48 Inches		0 Feet	70 Feet
18 Inches		70 Feet	1222 Feet
34 Inches		70 Feet	1220 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36"		.375	0	70
24"		.375	+3	620
			720	760
			1180	1200

Perforations:
Type perforation Houston S.S. 304 wire wrap screen
Size perforation .100 slot
From 620 feet to 720 feet
From 760 feet to 1180 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 300
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 300 feet to 1220 feet

9. WATER LEVEL
Static water level 494.11 feet below land surface
Artesian flow NO G.P.M. ____ P.S.I.
Water temperature N A °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Zim Industries, Inc. Contractor
Address 4545 E. Lincoln Ave. Contractor
Fresno CA 93725
Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1697
Signed C. Mitchell By driller performing actual drilling on site or contractor
Date 10-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627