WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57866
Permit No.
Basin 162

NOTICE OF INTENT NO. 14953

1. OWNER Robert & Linda Farmer
MAILING ADDRESS 3330 S Tournament
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
3330 S Tournament

2. LOCATION SW 1/4 NW 1/4 Sec. 34 T 20S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
40-661-10 Parcel No.
Calvada Valley 4A Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Reconditon
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	20	20
Brown Clay		20	41	21
Brown Clay		41	63	22
Brown Clay		63	81	18
Light Brown Clay	x	81	101	20
Light Brown Clay	x	101	120	19
Light Grey Clay	x	120	139	19
Beige Clay	x	139	158	19
Light Brown Clay	x	158	170	12

NOV 27 1996

Date started 10/15/96, 19__
Date completed 10/16/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	N/A	.50

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	170 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	170

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 90 feet to 110 feet
From 130 feet to 150 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 11-25-96