WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57892
Permit No.
Basin 162

NOTICE OF INTENT NO. 14951

1. OWNER Cliff Weisenhunt
MAILING ADDRESS 4431 e Ashley Ave.
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
4431 E Ashley Ave.

2. LOCATION NE 1/4 NW 1/4 Sec. 29 T 21S N/S R 54E E Nye County
PERMIT NO. _____ Issued by Water Resources
45-322-03 Parcel No.
Green Saddle Ranch Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	17	17
Grey Clay		17	33	16
Light Grey Clay		33	50	17
Brown Clay	x	50	66	16
Light Brown Clay	x	66	80	14
Brown Calichia	x	80	99	19
Light Brown Clay	x	99	118	19
Cream Clay	x	118	140	22

OCT 18 1996

Date started 10/2/96 , 19__
Date completed 10/3/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation torch
Size perforation .25 x 6
From 110 feet to 130 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board. 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Gary Strickland
By driller performing actual drilling on-site or contractor

Date 10·16·96