WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 57893
Permit No.
Basin 162

NOTICE OF INTENT NO. 14962

1. OWNER Wild West Homes
MAILING ADDRESS Flamingo St.
Pahrump, NV 89041

ADDRESS AT WELL LOCATION Flamingo St

2. LOCATION SE 1/4 SW 1/4 Sec. 23 T 20000S N/S R 52E E Nye County
PERMIT NO. _____ Issued by Water Resources
28-463-04 Parcel No.
Rancho Vista Estates Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Red Clay		0	15	15
Calichia		15	35	20
Calichia		35	56	21
Grey Clay	x	56	78	22
Light Brown Clay	x	78	98	20
Dark Brown Clay	x	98	119	21
Brown Clay	x	119	140	21

OCT 18 1996

Date started 10/15/96 , 19__
Date completed 10/15/96 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
_____ Inches		_____ Feet	_____ Feet
_____ Inches		_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 96 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916

Signed Gary Strickland
By driller performing actual drilling on-site or contractor
Date 10-17-96