

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 57931
 Rec. _____
 Well No. _____
 Permit No. _____
Do not fill in

Owner EDWARD P. GROVER Driller LOUIS F. EVANS
 Address 833 CLARKWAY DRIVE, LAS VEGAS, NEVADA Address 2020 CARROLL N. LAS VEGAS Lic. No. 117
 Location of well: S.W. 1/4 SW 1/4 Sec. 5., T.22 N/S, R. 61 E, in CLARK County _____
 or _____
 Water will be used for DOMESTIC Total depth of well 200 ft.
 Size of drilled hole 55 ft. 12 inch. 145 ft. 10 inch Weight of casing per linear foot 11 lbs.
 Thickness of casing 10 gauge Temp. of water _____
 Diameter and length of casing 8 inch O.D. casing 200 ft.
 (Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)
 If flowing well give flow in c.f.s. or g.p.m. and pressure _____
 If nonflowing well give depth of standing water from surface 132 ft.
 If flowing well describe control works _____
 (Type and size of valve, etc.) _____
 Date of commencement of well OCT. 14, 1955 Date of completion of well OCT. 26, 1955
 Type of well rig ARMSTRONG

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0)	2	2	top soil
2	17	15	sandy clay & gravel
17	30	13	clichi & gravel
30	37	7	clay
37	50	13	cement gravel
50	63	13	clay & gravel
63	68	5	cement gravel
68	79	11	clay & gravel
79	95	16	cement gravel
95	102	7	gravel
102	107	5	brown clay
107	113	6	brown clay & gravel
113	118	5	gravel
118	127	9	brown clay & gravel
127	132	5	gravel
132	140	8	brown sandy clay
140	143	3	gravel (water)
143	170	27	brown clay & gravel (water)
170	200	30	gravel (water)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
 from 170 to 200 ft.

Other aquifers 140 to 143
143 to 170

First water at 140 feet.

Casing perforated
 from 140 to 200 ft.

Size of perforations
1/4 inch wide 6 inches long

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 inch.	0	200	200	GRAVEL PACKED 145 ft. from 55 ft. to 200 ft. CEMENTED 55 ft. from 0 to 55 ft.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Louis F. Evans
Well Driller

By ROBERT MAGNESS

License No. 117

Dated OCT. 27, 19 55

(Not to be filled in by Driller)
