WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58029
Permit No.
Basin 089

NOTICE OF INTENT NO. 29032

1. OWNER Bob Oglesby
MAILING ADDRESS 7635 Old 395 N.
Carson City, NV 89704

ADDRESS AT WELL LOCATION
7635 Old 395 N.

2. LOCATION SW 1/4 NE 1/4 Sec. 26 T 16N N/S R 19E E Washoe County
PERMIT NO. ~~392748-276~~ (Issued by Water Resources) 055-310-27 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	3	3
Yellow Clay		3	5	2
Multi colored course gravel		5	20	15
Boulders		20	31	11
Brown Clay		31	40	9
Smaller boulders		40	54	14
Grey clay		54	56	2
Black granite w/ grey rock		56	75	19
Blue clay		75	82	7
See next line	xx	82	127	45
Black granite w/blue rock and water stained				

Date started 6/26/96 , 19__
Date completed 6/28/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	90	3 hr.

8. WELL CONSTRUCTION
Depth Drilled 127 Feet Depth Cased 127 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	127 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	127

Perforations:
Type perforation Factory
Size perforation .060 x 3" 8 around
From 107 feet to 127 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 127 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 6 G.P.M. 5 P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
RENO, NV 89511

Nevada contractor's license number issued by the State Contractor's Board 23096

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719

Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor

Date 7-11-96