WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58049
Permit No.
Basin 162

NOTICE OF INTENT NO. 14954

1. OWNER Susan Ficher
MAILING ADDRESS 9621 S Homestead
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
9621 South Homestead

2. LOCATION NW 1/4 SW 1/4 Sec. 31 T 21S N/S R 54E E Nye County
PERMIT NO. (Issued by Water Resources) 45-431-28 (Parcel No.) Cal Vista (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	15	15
Grey Calichia		15	22	7
Brown Clay		22	38	16
Brown Clay		38	60	22
Brown Calichia		60	79	19
Grey Clay		79	100	21
Brown Clay	x	100	122	22
Light Brown Popcorn	x	122	140	18
Light Brown Calichia	x	140	163	23
Sand & Gravel	x	163	180	17
Sand Gravel	x	180	200	20

Date started 11/2/96, 19__
Date completed 11/2/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n/a	.50

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 168 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Larry Strickland (By driller performing actual drilling on-site or contractor)
Date 11-25-96

NOV 27 1996