WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58050
Permit No.
Basin 162

NOTICE OF INTENT NO. 14960

1. OWNER Oscar Clark
MAILING ADDRESS 1081 E Thousandaire
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
1081 E. Thousandaire

2. LOCATION NW 1/4 NW 1/4 Sec. 14 T 21S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 44-701-05 (Parcel No.) Mesa Oesta Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	3	3
Light Grey Calichia		3	10	7
Dark Grey Calichia		10	28	18
Light Grey Calichiia		28	42	14
Light Grey Calichia		42	64	22
Light Grey Calichia		64	85	21
Light Grey Calichia	x	85	104	19
Light Brown Calichia	x	104	125	21
Light Brown Clay	x	125	140	15
Brown Clay	x	140	158	18
Popcorn	x	158	179	21
Brown Clay	x	179	200	21

NOV 27 1996

Date started 11/4/96, 19__
Date completed 11/4/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	N/A	.56

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	200

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 140 feet to 170 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Gary Strickland (By driller performing actual drilling on-site or contractor)
Date 11.25.96