WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58051
Permit No.
Basin 162

NOTICE OF INTENT NO. 14965

1. OWNER Gene & Marion Spiller
MAILING ADDRESS 3581 S Oakleaf
Pahrump, NV 89041

ADDRESS AT WELL LOCATION
3581 S Oakleaf

2. LOCATION SW 1/4 SE 1/4 Sec. 31 T 20S N/S R 53E E Nye County
PERMIT NO. _____ Issued by Water Resources
41-161-07 Parcel No.
Calvada Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Brown Clay		10	25	15
Light Brown		25	40	15
Light Grey		40	59	19
Grey Calichia		59	72	13
Light Brown Clay		72	93	21
Dark Brown Calichia	x	93	114	21
Creamy Calichia	x	114	130	16
Light Grey Popcorn Calichia	x	130	155	25

Date started 11/5/96, 19__
Date completed 11/5/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n\a	.50

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	155 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	155

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 133 feet to 155 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 155 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Gary Strickland
By driller performing actual drilling on-site or contractor
Date 11.25.96