WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58052
Permit No.
Basin 162

NOTICE OF INTENT NO. 14967

1. OWNER Vondell & JoAnn Suter
MAILING ADDRESS 170 S. David
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
170 S. David

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T 20S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 36-272-25 (Parcel No.) Cal Vegas Ranchos (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	3	3
Grey Clay		3	15	12
Light Brown		15	30	15
Light Brown		30	48	18
Light Brown		48	64	16
Brown Popcorn	x	64	82	18
Brown Popcorn	x	82	99	17
Cream Clay	x	99	118	19
Brown Clay	x	118	140	22

NOV 27 1996

Date started 11/8/96 , 19__
Date completed 11/8/96 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	n\a	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation Torch
Size perforation .25 x 6
From 107 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 2301 Winery Road, Suite 2 (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Tom Strickland (By driller performing actual drilling on-site or contractor)
Date 11-25-96