

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12211

1. OWNER Dick Ward ADDRESS AT WELL LOCATION Mile Marker 102  
 MAILING ADDRESS 2140 Eagleland US 93, 7 miles North of Caliente  
Henderson, NV 89014 1/2 mile West  
 2. LOCATION N/E 1/4 N/W 1/4 Sec. 2 T. 3 N. R. 67 E. Lincoln County  
 PERMIT NO. 0 Issued by Water Resources Parcel No. 6 Subdivision Name 0

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil - Boulders		0	35	35
Sand - Boulders		35	90	55
Clay - Gravel	X	90	180	90
Clay		180	190	10
TD 190'				

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>0</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1 3/4" x 6"  
 From 110 feet to 130 feet  
 From 150 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 190 feet

Date started 10-21-96, 19\_\_\_\_  
 Date completed 10-26-96, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>14</u>	<u>10</u>	<u>4</u>

9. WATER LEVEL  
 Static water level 8.6 feet below land surface  
 Artesian flow 0 G.P.M. 0 P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Dev's Drilling - Pompey Contractor  
 Address PO. Box 54 Contractor  
14100 Nev. 89017  
 Nevada contractor's license number issued by the State Contractor's Board 0028966  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed Mike D. Davis  
 By driller performing actual drilling on site or contractor  
 Date 11-15-96