WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58081
Permit No.
Basin 230

NOTICE OF INTENT NO. 15190

1. OWNER GARCIA, NATIVIDAD
MAILING ADDRESS FISHER RD
AMARGOSA, NV

ADDRESS AT WELL LOCATION
FISHER RD AMARGOSA

2. LOCATION SW 1/4 SE 1/4 Sec. 12 T 17S N/S R 48E E NYE County
PERMIT NO. _____ Issued by Water Resources | 19-121-20 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other_____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	5	5
CALICHIE		5	20	15
CLAY		20	35	15
CALICHIE		35	45	10
CLAY		45	85	40
CALICHIE		85	88	3
CLAY		88	95	7
CALICHIE	WB	95	98	3
CLAY		98	115	17
CALICHIE	WB	115	122	7
CLAY		122	126	4
CALICHIE	WB	126	130	4
CLAY		130	134	4
CALICHIE	WB	134	140	6

DEC 4

Date started 10/14/96 , 19__
Date completed 10/18/96 , 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 100 feet to 120 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 95 feet below land surfac
Artesian flow _____ G.P.M. _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co.
Contractor
Address PO BOX 4220
Contractor
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dun
By driller performing actual drilling on-site or contractor

Date 11/4/96