


WELL DRILLER'S REPORT

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1755

OFFICE USE ONLY
Log No. 58149
Permit No. 219
Basin 219



1. OWNER TEXACO REFINING and Marketing

MAILING ADDRESS: 10 Universal City Plaza,

27th Floor, Universal City, CA 91608

ADDRESS AT WELL LOCATION: TEXACO MOANY LAB
VEGA TERMINAL, 5049-B N. SIERRA LANE,
LAS VEGAS, NV

2. LOCATION NE 1/4, SE 1/4 Sec. 33 T. 19 N. R. 62 E.

Clark County

PERMIT NO. MC-2726 520-580-003

Issued by Water Resources

Parcel No.

Subdivision Name

3. WORK PERFORMED

- New Well
 Replace
 Deepen
 Abandon
 Recondition
 Other

4. Domestic
 Municipal/Industrial

PROPOSED USE

- Irrigation
 Test
 Stock
 Monitor

5. WELL TYPE

- Cable
 Rotary
 Other Auger

LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silty Sand</u>		<u>0</u>	<u>48</u>	<u>48</u>
<u>Clayey Sand</u>		<u>48</u>	<u>56</u>	<u>8</u>
<u>Silty Sand</u>		<u>56</u>	<u>72</u>	<u>16</u>
<u>Silty Sand</u>		<u>72</u>	<u>76</u>	<u>4</u>
<u>Silty clay</u>		<u>>90'</u>	<u>76</u>	<u>121</u>
				<u>45</u>

8. WELL CONSTRUCTION

Depth Drilled 121 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

8 Inches From 0 Feet To 121 Feet

8 Inches From 0 Feet To 121 Feet

8 Inches From 0 Feet To 121 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>.70</u>	<u>.218</u>	<u>0</u>	<u>120</u>

Perforations: SLOTTED

Type perforation SLOTTED
Size perforation .01"

From 76 feet to 120 feet
From 76 feet to 120 feet
From 76 feet to 120 feet
From 76 feet to 120 feet

Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 65' Cement Grout
Placement Method: Pumped Concrete Grout
 Poured 4' of both mix placed in between

Gravel Packed: Yes No
From 69 feet to 121 feet

9. WATER LEVEL

Static water level 90 feet below land surface
Artesian flow 90 G.P.M. P.S.I.
Water temperature 90 °F Quality 90

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Thomas High Contractor

Address 731 Pilot rd, Suite H

Las Vegas, NV 89119

Nevada contractor's license number M1869
issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the gasite driller M1869

Signed [Signature] By driller performing actual drilling on site or contractor

Date 10/3/96

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M. (Feet Below State) Time (Hours)

Date started 6/25 19 96
Date completed 6/25 19 96