



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17566

1. OWNER SRK ADDRESS AT WELL LOCATION 3065 Sheridan St Las Vegas, NV  
 MAILING ADDRESS 1755 Phumb Lane Suite 241 Reno, NV 89502

2. LOCATION NW 1/4 SW 1/4 Sec 8 T 21 N 61 E Clark County  
 PERMIT NO. Mo-2739 / 162-08-302-016 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE M-4  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.4	.4
Basalt		.4	1	.6
Silty Sand		1	5	4
Silty Sand w/day		5	9	4
Silty clay		9	14.5	5.5
Sandy/silty clay		14.5	17.5	3
caliche		17.5	20	2.5

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 8 Feet  
 From 0 Feet To 20 Feet  
 From 0 Feet To 20 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.7	.218	0	20

Perforations:  
 Type perforation slotted  
 Size perforation .01, .02  
 From (.01) 5 feet to 15 feet  
 From (.02) 15 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 1.5  Neat Cement  Cement Grout  Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No 1.5' between filled with bentonite.  
 From 3 feet to 20 feet

9. WATER LEVEL  
 Static water level ~12 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7/30, 1996  
 Date completed 7/30, 1996

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thomas High Contractor  
 Address 731 Pilot Rd., Suite 4 Las Vegas, NV 89119 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date 10/3/96