WELL #2

1" Bad

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58156
Permit No. 62033
Basin 212

NOTICE OF INTENT NO. 15430

1. OWNER Southern Nevada Operating Engineers JATC
MAILING ADDRESS P. O. Box 4115
No. Las Vegas, NV 89036
ADDRESS AT WELL LOCATION 5500 Airport Road
Las Vegas, NV 89115

2. LOCATION NW-NW ¼ NE ¼ Sec. 34 T 19 N/S R 62 E Clark County
PERMIT NO. 62033 (Issued by Water Resources) 520-600-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Pop Corn Caliche		0	90	
Caliche		90	160	
Clay		160	255	
Clay & Water	X	255	270	
Clay		270	445	
Clay & Water	X	445	475	

Date started November 16, 1996
Date completed November 22, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 475 Feet Depth Cased 475 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼	Inches	0 Feet	70 Feet
10-5/8	Inches	70 Feet	475 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7-5/8	38.82	.500	+2	475

Perforations:
Type perforation Torch
Size perforation 3/16 x 6 row
From 435 feet to 455 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 70
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 70 feet to 475 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista Street (Contractor)
Las Vegas, NV 89129
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1745
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 12-3-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627