WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58157
Permit No. 61493
Basin 212

NOTICE OF INTENT NO. 17807

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 1001 South Valley View Blvd.
Las Vegas, NV 89153

ADDRESS AT WELL LOCATION Well # 115
8551 W. Gowan
Las Vegas NV 89129

2. LOCATION NE ¼ SE ¼ Sec. 8 T. 20 S N/S R. 60 E Clark County
PERMIT NO. 61493 (Issued by Water Resources) 138-08-701-013 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness

RECEIVED
96 OCT 21 PM 1:30
STATE ENGINEER'S OFFICE

Date started 4-16, 19 96
Date completed 8-20, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1860	60.42	24

8. WELL CONSTRUCTION
Depth Drilled 1317 Feet Depth Cased 1260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	70	Feet
18	Inches	70	Feet	1317	Feet
34	Inches	70	Feet	1280	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36"		.375	0	70
24"		.375	+3	540
		Steel	660	700

Perforations: Johnson S. ~~Steel~~ 304 1000 - 1040
Type perforation Wire wrap screen 240 - 1260
Size perforation .100
From 540 feet to 660 feet
From 700 feet to 1000 feet
From 1040 feet to 1240 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 300 feet to 1280 feet

9. WATER LEVEL
Static water level 408.2 feet below land surface
Artesian flow ND G.P.M. P.S.I.
Water temperature N/A °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Zim Industries, Inc. (Contractor)
Address 4545 E. Lincoln Ave. (Contractor)
Fresno CA 93725
Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1697
Signed C. Mitchell (By driller performing actual drilling on site or contractor)
Date 10-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627