WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58159
Permit No. 61494
Basin 212

NOTICE OF INTENT NO. 178066

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 1001 South Valley View Blvd
Las Vegas, NV 89153

ADDRESS AT WELL LOCATION Well # 114
8699 West Gowan
Las Vegas, NV 89129

2. LOCATION NE ¼ SE ¼ Sec. 8 T. 20-S N/S R. 60 E. Clark County
PERMIT NO. 61494 (Issued by Water Resources) | 138-08-701-013 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness

RECEIVED
96 OCT 21 PM 1:30
STATE ENGINEER'S OFFICE

Date started 4-16, 1996
Date completed 6-25, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☑ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2300	53.72	24

8. WELL CONSTRUCTION
Depth Drilled 1314 Feet Depth Cased 1270 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	70	Feet
18	Inches	70	Feet	1314	Feet
34	Inches	70	Feet	1290	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36"		.375	0	70
24"		.375	+3	550
			710	750

Perforations: Johnson SS, 304 1050 - 1090
1250 - 1270
Type perforation Wire wrap screen
Size perforation .100
From 550 feet to 710 feet
From 750 feet to 1050 feet
From 1090 feet to 1250 feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 300'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 300 feet to 1290 feet

9. WATER LEVEL
Static water level 426.80 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature N A °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Zim Industries, Inc. (Contractor)
Address 4545 E. Lincoln Ave. (Contractor)
Fresno CA 93725
Nevada contractor's license number issued by the State Contractor's Board 0037248
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1697
Signed C. Mitchell (By driller performing actual drilling on site or contractor)
Date 10-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627