

OFFICE USE ONLY  
 Log No. 58160  
 Permit No. \_\_\_\_\_  
 Basin 1162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 14975

1. OWNER Ben & Leora Brown ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3110 Kings Way  
Pahrump, NV 89048

2. LOCATION NW 1/4 SW 1/4 Sec. 18 T 21S N/S R 54E E nve County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. 45-201-61 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Brown Calichia		10	15	5
Grey Calichia		15	20	5
Light Brown Clay		20	38	18
Light Brown Clay		38	57	19
Light Grey Clay	x	57	80	23
Light Brown Clay	x	80	98	18
Light Grey Clay	x	98	118	20
Light Brown Clay	x	118	140	22

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
12 Inches 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Torch  
 Size perforation .25 x 6  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 50 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Strickland Construction Co., Inc. Contractor  
 Address 2301 Winery Road, Suite 2 Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board 40277  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 12-06-96



Date started 12/4/96 , 19\_\_\_\_  
 Date completed 12/4/96 , 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Baller <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>N/A</u>	<u>.50</u>