WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58177
Permit No.
Basin 212

NOTICE OF INTENT NO. 175664

1. OWNER: Las Vegas Sands, Inc.
MAILING ADDRESS: 3355 S. Las Vegas Blvd. Las Vegas, NV 89119
ADDRESS AT WELL LOCATION: 3355 S. Las Vegas Blvd., Las Vegas, NV

2. LOCATION: NW ¼ SW ¼ Sec. 16 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MO-2728 Issued by Water Resources
162-16-202-008 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE TW-1
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand		0	5	5
Sandy gravel		5	8	3
Gravelly Sand		8	11.5	3.5
Caliche		11.5	13	1.5
Gravelly Clay		13	14	1
Silty Clay		14	17.5	3.5
Gravelly Clay		17.5	20	2.5
Silty Clay		20	30	10
Sandy Clay		30	40	10
Silty Clay		40	60	

Date started 7/25, 19 96
Date completed 7/25, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	60 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.50	20	.237	0	55

Perforations:
Type perforation: slotted
Size perforation: .02"
From 5 feet to 55 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
2' of bentonite in between
Gravel Packed: ☒ Yes ☐ No
From 3 feet to 60 feet

9. WATER LEVEL
Static water level ~14 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High
Contractor
Address 731 Pilot Rd. Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed
By driller performing actual drilling on site or contractor
Date 10/3/96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627