WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELLS#44

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 58246
Permit No.
Basin 212
17487

NOTICE OF INTENT NO.

1. OWNER Kajima Construction
MAILING ADDRESS 2690 Chandler Ave. #2
Las Vegas, NV 89120

ADDRESS AT WELL LOCATION Gardens East Projects
Las Vegas, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 26 T. 21 N/S R. 62 E. Clark County
PERMIT NO. DW 1048 (Issued by Water Resources)
Parcel No. 116-26-001-302
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 1 1/2" rock | | 0 | 8 | 8 |
| organic Matter | | 8 | 17 | 9 |
| Sandy Clay | | 17 | 30 | 13 |

Date started 5/29, 1996
Date completed 6/15, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | 36.71 | 1.250 | 0 | 30 |
| | | | | |

Perforations:
Type perforation Factory
Size perforation 1/4" x 2 1/2" x 3 rows @ 13
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 30 feet

9. WATER LEVEL
Static water level 4-6 feet feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board: 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1376
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627