LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	plus 1	350	351'	Cemented to 50'

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed 50 GPM from 240'

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Patrick H. Thompson
Well Driller

By.....

License No. 192

Dated 4/19, 1965

(Not to be filled in by Driller)