LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"	0	170	170	50 feet cement grout 1 20 feet pea gravel fill

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

10 gpm at 160 feet pumping level

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed NEVADA PUMP & SUPPLY CO.
Well Driller

By Thos. DeBruyn Da

License No. 133

Dated May 20, 19 55

(Not to be filled in by Driller)