LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8"OD	0	200	200	This well cemented in with 3½ yds 6 sack mix Ready-mix grout. (This well is gravel packed within 51 ft of surface.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailing test indicates this well will deliver 950 gal of water perhour.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed [signature]
Well Driller

By [signature]

License No. 137

Dated April 8th, 19 55

(Not to be filled in by Driller)